

RZ3/4

Hold-open system VdS tested and approved by the building authority

Product description

The DIBt building rules list requires proof of applicability for fire protection closures (a German technical approval from the building authority or a European technical approval). These approvals stipulate a hold-open system to keep the systems open during operation. The hold-open system must be suited for this task. Its applicability must be verified by means of a technical approval.

Type	Control unit	Fire alarm analysis	Push-button • Via fire alarm loop or smoke switch • Potential-free contact of fire alarm centre
Proof of usability	UL 864		
Verification	Z-6.5-1484	Degree of protection	IP 65
