

## RZ8

Release device with energy supply (Z-6.510-2428)

### Product description

Release device with energy supply for the installation of a hold-open device RZ8-FA according to the general type approval Z-6.500-2436

<b>Product designation</b>	Power supply with trigger device	<b>Operation / display</b>	Membrane keypad
<b>Rated voltage</b>	85...265V AC	<b>Casing (type)</b>	Spelsberg (ABS)
<b>Connected load</b>	65VA	<b>Casing (size)</b>	122x122x55 mm
<b>Control voltage</b>	24V DC	<b>Casing (colour)</b>	similar to RAL 7038
<b>Mains frequency</b>	47...63Hz	<b>Degree of protection</b>	IP 65
<b>Starting current</b>	10A	<b>Ambient temperature</b>	-10°...+40°C
<b>Output current</b>	900mA DC		

#### Note

The RZ8 unit combination must be installed in the detection range of the fire detectors of the respective termination; if necessary, an additional fire detector must be installed. Other housing versions, e.g. flush-mounted, operating protection, cabinet installation, are possible; further information can be found in the operating instructions.